15 May 2025

Tier IV Certification of Constructed Facility for Atlantic Data Infrastructure (ADI) – Data Center Euskadi Bizkaia, Phase 1, Day 1 in Bilbao, Spain

Dear Alex Etxeberria Aranburu,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Constructed Facility for the Atlantic Data Infrastructure (ADI) – Data Center Euskadi Bizkaia, Phase 1, Day 1 as fulfilling Tier IV Fault Tolerant criteria. The Tier Certification is based on the design, facility demonstrations, and the on-site verification of the constructed facility that was completed 10 April 2025 and documentation subsequently submitted through 13 May 2025.

This Certification recognizes that Atlantic Data Infrastructure (ADI) – Data Center Euskadi Bizkaia, Phase 1, Day 1 is capable of supporting any planned work or unplanned event on the site infrastructure without disrupting more than the redundant computer room power and cooling capacity. This Tier IV Certification is limited by the as-demonstrated total IT load of 565 kilowatts (kW). This includes 562 kW in the data hall and 3 kW in mutually redundant Meet-Me Rooms MMRs A and B.

Tier IV Fault Tolerant criteria are founded on the capability to detect and isolate a fault within a facility's critical systems while sustaining the critical load and without an impact to the delivery of power and cooling to the critical areas. Although the systems are designed with Fault Tolerant criteria, certain operations-related errors, such as inadvertent activation of system-level EPO features, or malicious intervention, may still impact critical load.

This Tier Certification is valid until the facility is modified, including any changes to the capacity components or distribution paths depicted in the design identified above, and submitted for review. This Certification is subject to the limitations set forth in Schedule I hereto and incorporated herein.

This Tier IV Certification of Constructed Facility represents Atlantic Data Infrastructure's continued investment and commitment to site uptime availability.

Congratulations on this significant achievement.

Sincerely,

Christopher Brown
Chief Technical Officer