

Alex Etxeberria Aranburu
Director General
Data Center Euskadi, S.L.
Plaza Pio Baroja N 3-1
Bilbao, Bizkaia
Spain

7 April 2025



Tier IV Certification of Design Documents for Atlantic Data Infrastructure (ADI) – Data Center Euskadi Bizkaia, Phase 1 in Bilbao, Spain

Dear Alex Etxeberria Aranburu,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the Atlantic Data Infrastructure (ADI) – Data Center Euskadi Bizkaia, Phase 1 as fulfilling Tier IV Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 3 February and 31 March 2025.

This Certification supersedes the Tier IV Certification of Design Documents for Atlantic Data Infrastructure (ADI) – Data Center Euskadi Bizkaia, Phase 1 with 5 May 2025 expiry.

This Certification recognizes that Atlantic Data Infrastructure (ADI) – Data Center Euskadi Bizkaia, Phase 1, is capable of supporting any planned work or unplanned event on the site infrastructure without disrupting more than the redundant computer room power and cooling capacity. This Tier IV Certification is limited by the stated total IT load of 971 kilowatts (kW) over two discrete phases. Day 1 includes 487 kW, composed of a 484-kW IT load in the data hall and 3 kW in mutually redundant Meet-Me Rooms MMRs A and B. Day Final includes an additional 484 kW in the data hall for a total data hall load of 968 kW.

Tier IV criteria are founded on the capability to detect and isolate a fault within a facility's critical systems while sustaining the critical load and without an impact to the delivery of power and cooling to the critical areas. Although the systems are designed with Fault Tolerant criteria, certain operations-related errors, such as inadvertent activation of equipment-level EPO features, or malicious intervention, may still impact critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier IV Certification of Design Documents award is valid until 7 April 2027, subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,



Christopher Brown
Chief Technical Officer